


CLASSIFICATION
NOT PROTECTIVELY MARKED



Fenced Perimeter

Underground Gas Pipe Route to Power Station PRI

National Grid Distribution HP Gas Main

Above-ground Gas Pipe Route to Power Station PRI

Access Gates

Pig Trap

Isolation Valve

Fiscal Flow-meter (optional)

Isolation Valve

Valved and Plugged Vent

Bypass valve

Manual Isolation Valve

Isolation Joint

Emergency Egress Gate

Fenced Perimeter

ATKINS

ATKINS
Power Generation
8 Mallard Way
Strathclyde Business Park
Bellshill
ML4 3BF

CLIENT
Meaford Energy Limited

PROJECT
Meaford Energy Centre

TITLE
AGI

Indicative Layout			
DRAWN	DATE	CHECKED	APPROVED
LM	01/04/14	AB	DE
			01/04/14
			01/04/14

PROJECT NUMBER	DRAWING NUMBER	FILE NUMBER	SHEET No.	REV
5105324		002	1 OF 1	A

CLASSIFICATION
NOT PROTECTIVELY MARKED

MATERIAL
UNLESS OTHERWISE STATED DIMENSIONS ARE IN MILLIMETERS TOLERANCES UNLESS OTHERWISE STATED ARE TO BE IN ACCORDANCE WITH BS EN 22768:1993 PARTS 1&2 TOLERANCE CLASS 'C' COARSE

CLASSIFICATION
NOT PROTECTIVELY MARKED

THIS IS A CAD CREATED DRAWING THIS DRAWING IS NOT TO BE MODIFIED BY HAND DO NOT SCALE

MASS	SIZE	SCALE
kg	A3	

